

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0328:165 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Potter, 2081 Craig Road, St. Louis, MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Model *RA-LED32 Main Annunciator Chassis and Model *RA-LED48 Adder Annunciator Chassis. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-29 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciators for use with listee's separately listed compatible fire alarm control unit.

XLf: 7120-1477:107

*Corrected 09-24-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 24, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager